



1525 Broadway Longview, WA 98632 www.ci.longview.wa.us

Legislation Details (With Text)

File #: RS 17 2207 Version: 1 Name: RESOLUTION NO. 2207 - EMERGENCY

DECLARATION FIR STREET SEWER REPAIRS

Type: Resolution Status: Passed

File created: 2/2/2017 In control: City Council
On agenda: 2/9/2017 Final action: 2/9/2017

Title: RESOLUTION NO. 2207 - EMERGENCY DECLARATION FIR STREET SEWER REPAIRS

Sponsors:

Indexes:

Code sections:

Attachments: 1. Res #2207 - Emergency Declaration Fir Sewer Main

Date	Ver.	Action By	Action	Result
2/9/2017	1	City Council	adopted	Pass

RESOLUTION NO. 2207 - EMERGENCY DECLARATION FIR STREET SEWER REPAIRS

COUNCIL INITIATIVE ADDRESSED:

Provide sustainable water quality & environmental infrastructure Improve streets and roads

CITY ATTORNEY REVIEW: REQUIRED

SUMMARY STATEMENT:

On January 9, 2017, a small section of Fir Street between 18th & 19th Avenues collapsed into a sinkhole. Further investigation revealed the sinkhole was caused by a collapse of the 12-inch sewer main, and groundwater and sediment was filling the sewer pipe. Due to the risk of further roadway collapse, blockage of sewer flow in the pipe, and danger to the health and safety of the public, efforts began immediately to make the site safe and to retain a contractor to perform an emergency repair.

Under RCW 39.04.280, the city manager may declare an emergency and direct staff to respond to the emergency situation, and may award all contracts necessary to address the emergency. All such contracts must be reported to the City Council no later than two weeks after award, and the City Council must adopt findings and ratify the declaration of an emergency. Resolution No. 2207 will adopt findings and ratify the emergency declaration.

FINANCIAL SUMMARY:

The cost to replace and line the sewer main is estimated to be \$125,000. This emergency work will be funded by the Sewer Construction Fund.

RECOMMENDED ACTION:

Motion to adopt Resolution No. 2207.